



Town of Mason

12157 Main Street
Mason TN 38049
901-294-3525 Phone

PUBLIC WORKS REPORT February 23, 2026

Water:

- Water meters were read as usual from the 15th to the 25th of the month.
- Repaired three water leaks.
- All BACT Samples were negative.
- Installed 37 new meters.
- Sanitary survey at water plant was done on 02/11/2026 and waiting for results from TDEC.

Sewer:

- Three jet outs were done.
- Lift station on Charleston Mason Rd is being pumped twice daily and needs to be repaired ASAP.

Streets:

- Cleaned ditches in some areas.
- Picked up trash around the streets.
- All ice was removed for Richland Hills, Beaver Creek, and Gainesville Lane.

Gas

- All material for Charleston Fire Department is in, and the tap should be done next week.

Mr. Hall PWD