



Town of Mason

12157 Main Street
Mason TN 38049
901-294-3525 Phone

PUBLIC WORKS REPORT March 16, 2026

Water:

- Water meters were read as usual from the 15th to the 25th of the month.
- Repaired one water leak.
- All BACT Samples were negative for the month of February.
- Poplar Grove increased sample prices from \$48 to \$52.
- TDEC requested new order of test chemicals and test equipment for lab.
- Water tap was installed at Charleston Fire Dept.

Sewer:

- Sewer rehab project on Hwy. 59 has been completed.
- Lift station on Charleston Mason Rd is being pumped twice daily and needs to be repaired ASAP. We are discussing with the company that is doing the sewer rehab project on rebuilding lift station on Charleston Mason Rd.
There was money left over from the sewer rehab project that can be used to rebuild the lift station on Charleston Mason Rd.

Streets:

- Cleaned ditches in some areas.
- Picked up trash around the streets.

Gas

- Gas meter was installed at Charleston Fire Dept.