

May 18, 2026

PUBLIC WORKS REPORT

Water:

- All bac-t samples for April were negative of any coliform.
- Water meters were read as usual from the 15th to the 25th of the month.
- TDEC is requesting chlorine alarms be replaced in chlorine gas feeding and chlorine bottle storage rooms.
- Second motor has been installed in the water booster station on Hwy. 59.
- Five water leaks were repaired.
- 175 new water meters were installed.

Gas:

- Checked odorant at regulator station.
- Completed one gas tap.

Sewer:

- New motor installation by Cottrell Electric at Mason Charleston lift station to be done on May 14, 2026.
- Richland Hills lift station in need of two new dual head vacuum pumps.
- Kept up maintenance on lift stations on Richland Hills and Beaver Creek.
- Pumped sewer done twice a day seven days a week on Mason Charleston Rd.

Street:

- Cutting grass on streets and water tower areas as needed.
- Cleaning ditches on necessary streets.

A handwritten signature in black ink, appearing to read "M. Hall". The signature is written in a cursive, slightly slanted style.