

08/16/2026

PUBLIC WORKS REPORT

Water:

- All bac-t samples for July were negative of any coliform.
- Water meters were read as usual between 15th and 25th of the month.
- There should be around 85 new meters left to install
- Public Works made 1 water tap
- Public Works keeping close eye on Hwy 59 Booster station pump one has a slight roar

Gas:

- Tennessee Public Utility Commission (TPUC) is requesting drug and alcohol plan
- Mr. Allan Smith is working hard trying to keep gas records in order.

Sewer:

- Mason Charleston Lift Station is still doing well; had to remove dish rag from pump one morning
- Richland Hills lift station is running on one pump while pump one is having seal replaced
- The one pump at Richland Hills is keeping up well.
- Public Works answered 2 sewer back-up calls
- All grass in sewer lift station has been cut and sprayed

Streets:

- No grass cutting on streets or in parks total concentration on installing new water meters