

09/21/2026

PUBLIC WORKS REPORT

Water:

- All bac-t samples for August were negative of any coliform.
- All reports were sent to state and approved.
- New well installed behind fire station has been flushed. We are waiting for sample results.
- All no-read water meters have been installed. Deadline of 08/31/2026 was met.
- Public Works made 1 water tap
- Public Works keeping close eye on Hwy 59 Booster station pump one has a slight roar

Gas:

- Tennessee Public Utility Commission (TPUC) is requesting drug and alcohol plan
- Mr. Allan Smith is working hard trying to keep gas records in order.

Sewer:

- Mason Charleston Lift Station is still doing well; The discharge line installed by Cottrell Electric did split so we replaced it with new line.
- We still need to find someone to clean grease from Richland Hills station before pumps will function properly.
- Public Works answered 1 sewer back-up calls

Streets:

- Cutting grass on streets and in parks as necessary.